MEETING OF MAYOR AND BOARD OF ALDERMAN

PUBLIC WORKS REPORT

07/25/2022

WATER / GAS / SEWER / SEWER LAGOONS / STREETS / PARK

Item 1. Water

In Month of June 2022, we produced 13.566 MG of finished water.

Max Day was 0.581 MG.

Min Day was 0.381 MG.

Ave. Day was 0.452 MG.

Repaired five water leaks in system.

Major water leak on 07/13/2022 caused by Blue Oval; causing Scrub Oaks area to lose water.

There were two new water taps made in system.

Still having communication problems at Hwy. 59 water booster station.

Item 2. Gas

Sniff test have been done for month of July 2022.

We still need to bypass gas regulator station at Richland Hills entrance from accident.

Annual Review of all gas manuals have been done by Tri-Star Energy.

Item 3. Sewer / Sewer Lagoons

Lift Station on Mason / Charleston Road has been repairer, cost to repair $11,477.90.

Cutting grass and cleaning around lagoons.

Item 4. Streets

Prices on paving Gainesville Lane and Mason Charleston Road. Estimated cost

$105,000 each street.

Patching potholes in streets as needed.

Item 5. Park

Looking at putting fall break material in park playground areas.