

MEETING OF MAYOR AND BOARD OF ALDERMAN

PUBLIC WORKS REPORT

03/15/2021

WATER / GAS / SEWER / SEWER LAGOONS / STREETS / PARK

Item 1. Water

In Month of January 2021, we produced 14.508 MG of Raw water.

Max Day was 0.721 MG of Raw.

Min Day was 0.336 MG of Raw.

Ave Day was 0.518 MG of Raw.

Water Loss Reports are due.

We have several water leaks in systems that need attention when time allows .

Item 2. Gas

Gas survey for 2021 has been completed. We are waiting for results.

Odorant has been added to natural gas system.

Gas 7100 Incident Report has been file electronically .

Gas class was held on 03/11 and 03/12/21 for new employees and operator qualifications.

Item 3. Sewer / Sewer Lagoons

We were notified by Public Entity Partners after their inspection of sewer lagoons that a fence at sewer lift must be put back up. The cost of the new gate will be \$650.00.

Pond 3 is blending with pond 5, there is a blockage causing problem. State had been notified.

Aerators are off on ponds 5 and 6 to save energy during winter months.

Item 4. Streets

We are looking to purchase a small riding lawn mower for water towers and town hall yards.

I would like to purchase a new side cutting mower for street and sewer lagoons.

John Deere tractor for street cutting needs servicing.

Item 5. Park

Still Closed.

